



**CIVIL AVIATION AUTHORITY OF NEPAL
ELECTROMECHANICAL DEPARTMENT**

Sinamangal, Kathmandu, Nepal

BID ADDENDUM NOTICE

IFB NO.: NCB-04-EMD-EE-082/83

Date of Publication 26th Kartik 2082 (12th November 2025)

This is to notify all the concerned bidders that addendum has been issued for the **National Competitive Bidding** title "SUPPLY, DELIVERY, LAYING AND TESTING OF 11KV HT POWER CABLE FOR VOR/DME AT BIRATNAGAR AIRPORT" published on 2nd Kartik 2082 (19th October 2025) through PPMO's e-GP system www.bolpatra.gov.np/egp.

Addendum:

S.N.	Relevant Clause	Existing Clause	Modified Clause
1	Section V. Schedule of Requirements Technical Specification (Cable length)	2200 meter (Cable shall be in single roll length. Joint in cable shall be treated as non compliance.)	2200 meter (Cable shall be supplied in maximum two rolls and only a single Joint in cable with manufacturer- approved jointing kits shall be acceptable. All hardware and interfaces (recommended by the manufacturer) necessary for jointing the cable shall be supplied by the bidder. The bidder shall construct the required manhole at the cable joint as directed by the EMD according to site condition and the offer shall be inclusive of such cost.)

